

**CERTIFICATE OF CONFORMANCE  
EUROPEAN COMMUNITY  
COUNCIL DIRECTIVE 2004/108/EC**

**Date of Issue:** July 2011

**Issued By:** Retlif Testing Laboratories  
3131 Detwiler Road  
Harleysville, PA 19438

**Issued To:** Ovation Products / Division of DTG  
3864 Courtney Street  
Bethlehem, PA 18017

**Reference:** Retlif Report Number R-1687P-1

Retlif Testing Laboratories hereby acknowledges that compliance testing in accordance with the below listed standards was performed on a representative sample of the equipment listed below. Retlif Testing Laboratories further acknowledges that the test sample listed below was found to be in compliance with these standards.

This certificate is hereby issued to the above named grantee and is valid only for the equipment identified below.

**Manufacturer:** Ovation Products / Division of DTG  
3557 Progress Drive  
Bensalem, PA 19020

**Equipment Tested:** Pneumatic Control Module

**Model Number:** 111\_CTL Revision A

**Serial Number:** 200105

**Brand Name:** GRID-LOK

**Product Type:** Generic Heavy Industrial

**Note(s):** 1) See attached report R-1687P-1 for details and/or conditions pertaining to this certificate.

2) Conforms to the emissions requirements of EN 61000-6-4:2007:

CISPR 16-2-1 Edition 2.0:2008	Conducted Emissions
CISPR 16-2-3 Edition 3.0:2010	Radiated Emissions
IEC 61000-3-2 Edition 3.2:2009	Harmonics
IEC 61000-3-3 Edition 2.0:2008	Flicker

3) Conforms to the immunity requirements of EN 61000-6-2:2005:

IEC 61000-4-2 Edition 2.0:2008-12	Electrostatic Discharge
IEC 61000-4-3 Edition 3.1:2008-04	Radiated Immunity
IEC 61000-4-4 Edition 2.0:2004-07	EFT/Burst, Power Ports
IEC 61000-4-5 Edition 2.0:2005-11	Surge Immunity, Power Ports
IEC 61000-4-6 Edition 3.0:2008-10	Conducted Immunity, Power Ports
IEC 61000-4-8 Edition 2.0:2009-09	Power Frequency Magnetic Fields
IEC 61000-4-11 Edition 2.0:2004-03	Voltage Dips and Interrupts